

last update of Fuel for generators 31/07/2018

#	Hospital	Fuel available in the tank	Consumption of fuel (liter/hour)	Expected hours to run the Generators	Expected days to run the Generators 8/8	Expected days to run the Generators 6/12	Expected days to run the Generators 4/12
1	Shifa Hospital	76,800	615	124.878	10.41	6.94	6.24
2	Gaza European Hosp.	81,100	200	405.500	33.79	22.53	20.28
3	Pediatric Hosp.	4,150	80	51.875	4.32	2.88	2.59
4	Dorrah Hosp.	8,750	50	175.000	14.58	9.72	8.75
5	Pediatric Specialized Hosp.	10,080	50	201.600	16.80	11.20	10.08
6	Psychiatric Hosp.	1,270	30	42.333	3.53	2.35	2.12
7	Beit Hanoun Hosp.	11,035	23	479.783	39.98	26.65	23.99
8	Aqsa Hosp.	5,860	70	83.714	6.98	4.65	4.19
9	Nasser Hosp.-Khanyounis	69,800	170	410.588	34.22	22.81	20.53
10	Najjar Hosp.	8,950	45	198.889	16.57	11.05	9.94
11	Emirates Crescent (Tal Al Sultan) Hosp.	5,200	40	130.000	10.83	7.22	6.50
12	Indonesian hosp.	9,750	50	195.000	16.25	10.83	9.75
Total/liter		292,745					

